





Uhre Vandværk

Årsrapport 2020



Mængder

Udpumpet vandmængde:	Total:	89.959,9 m ³	Måler 1:	89.959,9 m ³	Måler 2:	1.862,7 m ³
Indvundet vandmængde:	Total:	96.741,0 m ³	Måler 4:	96.741,0 m ³		
Vand fra Brande	Måler 3:	2.841,4 m ³				

Forbrug

Elforbrug:	Total:	65.657,5 kWh	Udpumpet:	16.399,3 kWh
	Total:	0,73 kWh/m ³	Udpumpet:	0,18 kWh/m ³

Flow

Flow måler 1:

Min. Flow:	0,00 m ³ /h	Tidspunkt: 02-01-20 00:02:57
Max. Flow:	50,00 m ³ /h	Tidspunkt: 01-01-20 15:51:36

Flow måler 2:

Min. Flow:	0,00 m ³ /h	Tidspunkt: 01-01-20 00:00:00
Max. Flow:	20,00 m ³ /h	Tidspunkt: 01-02-20 08:02:00



Niveauer i boringer:

Boring 1 niveau: Højest: 0,00 m Lavest: -19,74 m Sænkning: 19,74 m

Filter:

Filter 1: Antal skyl: 473
Filter 2: Antal skyl: 160

Drifttimer:

	Periode:	Total:
Boring 1:	4219 Timer	29036 Timer
Pumpe 1:	2962 Timer	17081 Timer
Pumpe 2:	2904 Timer	16983 Timer
Pumpe 3:	2885 Timer	16939 Timer
Pumpe 4:	5617 Timer	34978 Timer