





Uhre Vandværk

Årsrapport 2024



Mængder

Udpumpet vandmængde:	Total:	81.019,9 m ³	Måler 1:	81.019,9 m ³	Måler 2:	2.011,3 m ³
Indvundet vandmængde:	Total:	116.047,0 m ³	Måler 4:	116.047,0 m ³		

Vand fra Brande

Måler 3: 1.424,5 m³

Forbrug

Elforbrug:	Total: 41.610,3 kWh	Udpumpet: 20.583,7 kWh
	Total: 0,51 kWh/m ³	Udpumpet: 0,25 kWh/m ³

Flow

Flow måler 1:

Min. Flow:	0,00 m ³ /h	Tidspunkt: 03-01-24 00:16:26
Max. Flow:	70,00 m ³ /h	Tidspunkt: 08-04-24 19:26:41

Flow måler 2:

Min. Flow:	0,00 m ³ /h	Tidspunkt: 01-01-24 00:00:00
Max. Flow:	20,00 m ³ /h	Tidspunkt: 07-08-24 21:57:39

Niveauer i boringer:

Boring 1 niveau:	Højest: 0,00 m	Lavest: -19,77 m	Sænkning: 19,77 m
Boring 2 niveau:	Højest: 0,00 m	Lavest: -52,38 m	Sænkning: 52,38 m

Filter:

Filter 1:	Antal skyl: 417
Filter 2:	Antal skyl: 173

Drifttimer:

Periode:

Total:

Boring 1:	4559 Timer	47773 Timer
Boring 2:	4 Timer	338 Timer
Pumpe 1:	2990 Timer	29649 Timer
Pumpe 2:	3378 Timer	29463 Timer
Pumpe 3:	3357 Timer	29422 Timer
Pumpe 4:	5513 Timer	57028 Timer