





Uhre Vandværk

Årsrapport 2025



Mængder

Udpumpet vandmængde:	Total: 110.011,0 m ³	Måler 1: 110.011,0 m ³	Måler 2: 2.022,8 m ³
Indvundet vandmængde:	Total: 117.840,0 m ³	Måler 4: 117.840,0 m ³	
Vand fra Brande	Måler 3: 785,0 m ³		

Forbrug

Elforbrug:	Total: 28.144,2 kWh	Udpumpet: 27.332,4 kWh
	Total: 0,26 kWh/m ³	Udpumpet: 0,25 kWh/m ³

Flow

Flow måler 1:

Min. Flow:	13,13 m ³ /h	Tidspunkt: 31-12-26 12:52:19
Max. Flow:	26,74 m ³ /h	Tidspunkt: 31-12-26 16:14:27

Flow måler 2:

Min. Flow:	0,00 m ³ /h	Tidspunkt: 31-12-26 12:52:19
Max. Flow:	10,21 m ³ /h	Tidspunkt: 31-12-26 23:14:09



Niveauer i boringer:

Boring 1 niveau:	Højest: -16,81 m	Lavest: -19,40 m	Sænkning: 2,59 m
Boring 2 niveau:	Højest: -20,20 m	Lavest: -43,95 m	Sænkning: 23,75 m

Filter:

Filter 1:	Antal skyl: 553
Filter 2:	Antal skyl: 226

Drifttimer:

Periode:

Total:

Boring 1:	3432 Timer	51214 Timer
Boring 2:	1559 Timer	1901 Timer
Pumpe 1:	4785 Timer	34454 Timer
Pumpe 2:	4925 Timer	34413 Timer
Pumpe 3:	5017 Timer	34441 Timer
Pumpe 4:	6160 Timer	63204 Timer